



St. MARTIN'S HIGH SCHOOL

CBSE Affiliation No. 3630111 School Code No. 57623

Madhav Nagar, Serilingampally, Miyapur, R.R. Dist. Hyderabad - 500 049.

Date: 18/09/2024

To,
The Commissioner,
HYDRA.

Dear Sir,

Sub: Submission of Self Certification form - acknowledgment - requested - reg

This is to inform you that our school St Martins High school established in the year 2001 and affiliated to Central Board Of Secondary School, Delhi with affiliation number 3630111. As per CBSE norms for every five years we have to renew our affiliation for which we have to submit application form along with FIRE NOC.

Our campus strictly abides by the rules & regulations of Fire department and had well equipped fire systems in our school for the safety of the students

In this regard, am hereby submitting self Certification Form for your kind perusal. Kindly acknowledge the form so as to submit the same for CBSE affiliation extension

Regards

G.Jai Kishan Yadav

Director

Mr. G. JAI KISHAN YADAV

St.Martin's High school Director

St. Martin's High School

Madhav Nagar Miyapur.

Miyapur





St. MARTIN'S HIGH SCHOOL

CBSE Affiliation No. 3630111 School Code No. 57623

Madhav Nagar, Serilingampally, Miyapur, R.R. Dist. Hyderabad - 500 049.

ANNEXURE -I

(Annexure to G.O.Ms.No.56, Home (Ser.IV) Department, Dated: 26.07.2019)

Instructions to Be Followed For School Existing Before 13.04.2009;

SELF CERTIFICATION FORM

Self Certification Of Fire Safety Measures By School Management:

1) General Information for School Buildings of all Categories i.e., A, B, C, D.

Sl. No.	Details	
1.	Date Of The Opening Of The School Building	12/06/2001
2.	Name Of Applicant	G.Jaikishan Yadav
3.	Name And Address Of The School	St.Martin's High School, Madhava Nagar, Miyapur, Hyderabad - 500049
4.	Telephone Number And Email Of Applicant	040-23045988, 9000215556 stmartinsmiyapur@gmail.com
5.	Height Of The Building (In Meters)	14.5 Mtrs
6.	No Of Floors	G + 4
7.	Abutting Road Width (In Meters)	9 Mtrs
8.	Built Up Area Of Each Floor in Sq.Mtrs	
	Ground	746.46
	1 st Floor	746.46
	2 nd Floor	746.46
	3 rd Floor	746.46
	4 th Floor	746.46
9.	Number Of Stair Case	1 x 1.50 = 1.50
	Stair Case 1 ----- (Width In Meters)	1 x 1.50 = 1.50
	Stair Case 2 ----- (Width In Meters)	
10.	Width Of Each Stair Case	1.50 Mtrs
11.	Open Spaces	
	Front	1.00 mt (Width In Mtrs)
	Side 1	1.50 mt (Width In Mtrs)
	Side 2	1.50 mt (Width In Mtrs)
	Rear	1.00 mt (Width In Mtrs)





St. MARTIN'S HIGH SCHOOL

CBSE Affiliation No. 3630111 School Code No. 57623

Madhav Nagar, Serilingampally, Miyapur, R.R. Dist. Hyderabad - 500 049.

A) School Building with Ground plus two floors and less than 15Meters in height.

Sl. No	Fire equipment as per norms	Scale of fire equipment as per norms	Required	Provided
1	Fire extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguishers ,for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 15 meters radius	40	50
2	First Aid Hose Reel (IS 884:1985)	1 No for every 1000 square meter	15	15
3	Terrace Tank over respective tower terrace	10000 Liters (5000 Liters additionally shall be provided if basement exceeds 200 square meters)	10000 ltrs	10000 ltrs
4	Automatic sprinkler system(IS 151505:2002), This IS standard may be downloaded from www.https://bis.gov.in/	To be installed in basement. If area exceeds 200 square maters	N/A	N/A
5	Pump capacity in LPM at the terrace tank level with minimum pressure of 3.5 kg/cm ²	450 LPM (450 LPM additionally shall be provided if basement exceeds 200 square meters)	1 NO- 450 LPM	1 NO- 450 LPM
Additional Fire Safety Measures in lieu of deficiency in Setbacks.				
1	Water Shower curtain	Water Shower curtain shall be provided in all floors on the side/sides having deficiency of setback to overcome exposure hazard from fires from neighboring property.	N/A	N/A
2	Fire Brigade inlet	02 No.s	2 NO'S	2 NO'S

Note: If the floor area in a single floor more than 500 square meters and if there is only single stair case, a second stair case of 1.5 Meters width shall be provided with concrete/Metal steel structure.



St. MARTIN'S HIGH SCHOOL

CBSE Affiliation No. 3630111 School Code No. 57623

Madhav Nagar, Serilingampally, Miyapur, R.R. Dist. Hyderabad - 500 049.

II) General Fire Safety Measures which should be followed by all schools:-

Sl. No	General Fire Safety Measures	Whether followed Yes/No
1	The school building shall not be housed in temporary structures with roofs of tent cloth, thatched or any other combustible materials.	Yes
2	It should be ensured that the available Fire Safety Equipment is always in good working condition.	Yes
3	Pre-School, Kinder Garden and Class/Grade 1 students shall be located on Ground Floor/ level of Exit discharge and Class/Grade 2 students shall be located not above One Floor higher than Ground Floor/ Level of Exit discharge.	Yes
4	Kitchen should be constructed/provided away from the school building	No Kitchen
5	All schools shall prepare an Evacuation Plan in consultation with local Fire Officer	Yes
6	All Teachers/Employees should be trained in operating the available Fire Safety Equipment in the building.	Yes
7	All Exits/Escape routes shall be kept free from any obstructions for free passage in case of any emergency.	Yes
8	All the internal staircases, lifts, lobbies and corridors should be adequately ventilated and illuminated.	Yes
9	If the school is provided with central Air-conditioning system, all safety measures as per Clause 10.1 of IS 14435:1997 should be followed.	No Centralized Air Conditioning system
10	School buildings shall be kept free from inflammable and toxic material. If storage is inevitable, they should be stored safety.	Yes
11	Any Hazardous/Combustible Material/Volatile Flammable Liquids shall not be stored in School Building	Yes
12	Dos and DON'Ts in case of any Fire/Emergency shall be properly displayed at Strategic locations of the building.	Yes
13	Auto Glow Sign Boards shall be provided indicating Exits/Escape Routes.	Yes
14	Electric Wiring in the entire building shall be checked and certified by the competent authority.	Yes



St. MARTIN'S HIGH SCHOOL

CBSE Affiliation No. 3630111 School Code No. 57623

Madhav Nagar, Serilingampally, Miyapur, R.R. Dist. Hyderabad - 500 049.

15	Structural Stability of the building shall be checked and certified by the competent authority	Yes
16	Public Address System shall be provided for use in case of any emergency and this system shall cover the entire building	Yes
17	Detailed information regarding the number of Students in each Class Room and the number of teachers/employees working shall be displayed at Strategic locations of the building.	Yes
18	Display all Emergency supporting numbers such as nearest Fire Stations, Police Stations, Hospitals/Ambulance etc., on all floors and Strategic locations.	Yes
19	A pictorial map with the details of Entries/Exits, details of Class Rooms/Laboratories/Staff Rooms and Open Place(Assembly Point) of the School Building shall be prepared and displayed in Strategic Locations.	Yes
20	If Basement area of the building exceeds 200 square meters, required to provide Automatic Sprinkler System as per IS 15105:2002	No Basements

We St.Martin's High School, Miyapur School Management/Correspondent hereby certify that the information furnished is correct and if it is noticed at any time that the information provided is false, we understand that our school affiliation may be cancelled by the Concerned Authority. We have installed fire safety measures as per the Annexure I and undertake to maintain the same in good working condition at all times.



Signature with date of
School authority and seal
Name & Designation:

Mr. G. JAI KISHAN YADAV
Director
St. Martin's High School
Miyapur.